TAMILNADU FIRE AND RESCUE DEPARTMENT, Kilpauk

Fire and Rescue Station. NO OBJECTION CERTIFICATE

Ref.No. 94/V/2026 **Date: 05.03.2026**

Certificate No. 16/2026

Ref :(1) G.O. No.122. School Edu (2) Dept, Date: 14.09.2004
(2) G.O. No.123 School Edu (2) Dept, Date: 14.09.2004
(3) Application received from the Principal of the school on 04/03/26

Based on the Govt. order mentioned above and the requisition letter given by **M/S. SIRMUTHA SCHOOL (Ground +Three Floor Only)** with address at **No.07, Harrington Road, Chetpet, Chennai -600031**.

The school was inspected on 004.03.3036 by the Assistant District Officer, Kilpauk. Mr. K.Sivasankaran and that the school is granted NOC at the given location from (05.03.3036 to 04.03.2029) and subject to the conditions stated below.

CONDITIONS

1. This License is Valid for Three Year from the date of issue.
2. Fire Safety Systems should be maintained in good working Conditions.
3. Mock Drill to be Conducted periodically with the help of local Fire Brigades.
4. Any erection of permanent or temporary structure should be intimated to this Department.
5. A Trained Fire Service Person preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
   a. Building occupancy capacity should not be more than 4 people per Sq. Metre as per the National Building Code-2005.
   b. The Staircase treads and flooring shall be treated with rough finish (grooving)to avoid falling of Children
   c. As para 6.3 of the BIS Standards Is 14435-1997 as the classrooms have only on entrance the capacity of the class rooms shall have to be limited to 45 students.
   d. Periodical maintenance and care should be taken to maintain all fire protection equipment's.
   e. Mock drill has to be conducted at regular intervals in consultation with the District officer Fire and Rescue Services, Chennai City Central District at Kilpauk.

Copy to:

Sir Mutha School ,
7, Harrington Road,
Chetpet , Chennai – 600031.

Sealed and Signed by
Assistant District Office
Fire & Rescue Station, Kilapuk , Chennai -10

Copy to District Officer, Chennai Central District, Kilpauk , Chennai – 10.

12.6.26

Lr. P. JAYACHANDRAN, B.Sc., B.L.,
NOTARY PUBLIC
C.M.M. COURT, EGMORE, CHENNAI-8.
CELL: 94444 55245
True Copy & Attested

L.P. JAYACHANDRAN, B.Sc., B.L. G.O.(MS) No:521/22 NOTARY, CHENNAI